STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	15E594	A. BUILDING **01** B. WING _____	R **08/12/2013**

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
MCGIVNEY HEALTH CARE CENTER	**2907 E 136TH ST** **CARMEL, IN 46033**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS	{K 000}		

A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 06/26/13 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).

Survey Date: 08/12/13

Facility Number: 000545
Provider Number: 15E594
AIM Number: 100267350

Surveyor: Mark Caraher, Life Safety Code Specialist

At this PSR survey, McGivney Health Care Center was found in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.

This one story facility with a lower level was determined to be of Type V (111) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and in all areas open to the corridor. The facility has smoke detectors hard wired to the fire alarm system installed in all resident sleeping rooms. The facility has a capacity of 37 and had a census of 32 at the time of this visit.

All areas where residents have customary access were sprinklered. The facility has one detached storage building providing facility services which

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	15E594	A. BUILDING **01** B. WING _____	R **08/12/2013**

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
MCGIVNEY HEALTH CARE CENTER	**2907 E 136TH ST** **CARMEL, IN 46033**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	Continued From page 1 was not sprinklered. Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 08/12/13.	{K 000}		